



AURANGABAD MUNICIPAL CORPORATION
FIRE BRIGADE
TELEPHONE NO-2334000-40FAX No-2331444

Outward No: AMC/FIRE / 55 /2021

Date 19 / 04 /2021

To,
President,
A B International Primary Secondary
& Higher Secondary English School,
Gut No. 107(PT), At. Pokhari Ta & Dist. Auragabad.

Sub:- Revised Provisional Fire NOC is issued to President, A B International Primary Secondary & Higher Secondary English School, Gut No. 107(PT), At. Pokhari Ta & Dist. Auragabad.

Ref:- 1) Your letter dated 02/03/2019 2) Provisional Noc date 05/03/2019
2) Your Letter dated 19/04/2021 4) CFO Inspection dated 19/04/2021

With Reference to the above subject Revised Provisional Fire NOC is issued to President, A B International Primary Secondary & Higher Secondary English School, Gut No. 107(PT), At. Pokhari Ta & Dist. Auragabad. Plot area is 10675.00 Sq.Mtr

| Sr. No | Name of Building | Height of Building Mtr. | Bild No. | No of floors | Total Area of Plot Sq.Mtr | Built/up area Sq.Mtr. | Fire Fund | NOC Fees |
|--------|---|-------------------------|----------|--------------|---------------------------|-----------------------|-----------|----------|
| 1 | Primary Secondary & Higher Secondary English School | 08.60 | 1 | 0 + 1 Floors | 10675.00 | 1071.44 | 000 | 10000 |

Following Fire prevention and Fire protection & Fire Fighting measures subject to The Primary Secondary & Higher Secondary English School Building shall be provided.

1. 4.50 Mtr Open space all around the building shall be provided for the movement of fire tender and which will carry 25 tons. weight capacity.
2. Overhead water tank 10000 lit capacity with the fire pump of suitable capacity for building shall be provided.
3. Down Commer having outlet on all floors with hose pipe / branch shall be provided.
4. Hose reel of 100 feet on all outlets shall be provided.
5. Fire Extinguisher of ABC/ Co2/ Soda Acid / Fire Buckets of suitable capacity / quantity shall be provided.
6. Use of All piped of TATA, Zenith, APL (Applo), or I.S.I. Mark for fire Hydrant system shall be provided.
7. All the above requirements shall be carried out with prior approval from fire Brigade.

As per BMC ACT -1949 section 376, Development control Rules of 1983 and Maharashtra Fire prevention & Life safety Measures Act 2006. Revised Provisional Fire NOC is issued to the President, A B International Primary Secondary & Higher Secondary English School, Gut No. 107(PT), At. Pokhari Ta & Dist. Auragabad.


Chief Fire Officer
Fire Brigade
Municipal Corporation Aurangabad

Copy to:- A D.T.P AMC, Aurangabad.


PRINCIPAL

A B INTERNATIONAL PRIMARY SECONDARY
& HIGHER SECONDARY ENGLISH SCHOOL

NOC